



David Wilson

E: [REDACTED]
M: [REDACTED]

West Berkshire Council

Issued via email:
planningpolicy@westberks.gov.uk1st Floor West
Clearwater Court
Vastern Road
Reading
RG1 8DB

29 August 2023

West Berkshire – Hermitage Neighbourhood Plan 2022-2039 (Regulation 16 consultation)

Dear Sir/Madam,

Thank you for allowing Thames Water Utilities Ltd (Thames Water) to comment upon the above.

As you will be aware, Thames Water are the statutory water supply and sewerage undertaker for the West Berkshire district and are hence a “**specific consultation body**” in accordance with the Town & Country Planning (Local Planning) Regulations 2012.

We have the following comments on the consultation in relation to our water supply and sewerage undertakings:

General Water and Wastewater Infrastructure Comments

A key sustainability objective for the preparation of Local Plans and Neighbourhood Plans should be for new development to be co-ordinated with the infrastructure it demands and to take into account the capacity of existing infrastructure. Paragraph 20 of the revised National Planning Policy Framework (NPPF), 2021, states: “*Strategic policies should set out an overall strategy for the pattern, scale and quality of development, and make sufficient provision for... infrastructure for waste management, water supply, wastewater...*”

Paragraph 11 states: “*Plans and decisions should apply a presumption in favour of sustainable development. For plan-making this means that:*

a) all plans should promote a sustainable pattern of development that seeks to: meet the development needs of their area; align growth and infrastructure; improve the environment; mitigate climate change (including by making effective use of land in urban areas) and adapt to its effects”

Paragraph 28 relates to non-strategic policies and states: “*Non-strategic policies should be used by local planning authorities and communities to set out more detailed policies for specific areas, neighbourhoods or types of development. This can include allocating sites, the provision of infrastructure...*”

Paragraph 26 of the revised NPPF goes on to state: “*Effective and on-going joint working between strategic policy-making authorities and relevant bodies is integral to the production*

of a positively prepared and justified strategy. In particular, joint working should help to determine where additional infrastructure is necessary....”

The web based National Planning Practice Guidance (NPPG) includes a section on ‘water supply, wastewater and water quality’ and sets out that Local Plans should be the focus for ensuring that investment plans of water and sewerage/wastewater companies align with development needs. The introduction to this section also sets out that *“Adequate water and wastewater infrastructure is needed to support sustainable development”* (Paragraph: 001, Reference ID: 34-001-20140306).

Thames Water therefore recommends that developers engage with them at the earliest opportunity (in line with paragraph 26 of the revised NPPF) to establish the following:

- The developments demand for water supply infrastructure;
- The developments demand for Sewage/Wastewater Treatment and network infrastructure both on and off site and can it be met; and
- The surface water drainage requirements and flood risk of the development both on and off site and can it be met.

Thames Water offer a free Pre-Planning service which confirms if capacity exists to serve the development or if upgrades are required for potable water, waste water and surface water requirements. Details on Thames Water’s free pre planning service are available at: <https://www.thameswater.co.uk/developers/larger-scale-developments/planning-your-development/water-and-wastewater-capacity>

In light of the above comments and Government guidance, the Neighbourhood Plan should include a specific reference to the key issue of the provision of wastewater/sewerage and water supply infrastructure to service development proposed in a policy. This is necessary because it will not be possible to identify all of the water/sewerage infrastructure required over the plan period due to the way water companies are regulated and plan in 5 year periods (Asset Management Plans or AMPs). We recommend that the Neighbourhood Plan include the following policy/supporting text:

“Where appropriate, planning permission for developments which result in the need for off-site upgrades, will be subject to conditions to ensure the occupation is aligned with the delivery of necessary infrastructure upgrades.”

“The Local Planning Authority will seek to ensure that there is adequate water and wastewater infrastructure to serve all new developments. Developers are encouraged to contact the water/waste water company as early as possible to discuss their development proposals and intended delivery programme to assist with identifying any potential water and wastewater network reinforcement requirements. Where there is a capacity constraint the Local Planning Authority will, where appropriate, apply phasing conditions to any approval to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of the relevant phase of development.”

Policy HER4 - Comments in Relation to Flood Risk and Sustainable Drainage Systems

The National Planning Practice Guidance (NPPG) states that a sequential approach should be used by local planning authorities in areas known to be at risk from forms of flooding other than from river and sea, which includes "Flooding from Sewers".

Flood risk sustainability objectives and policies should also make reference to 'sewer flooding' and an acceptance that flooding can occur away from the flood plain as a result of development where off site sewerage infrastructure and capacity is not in place ahead of development.

With regard to surface water drainage it is the responsibility of the developer to make proper provision for drainage to ground, watercourses or surface water sewer. It is important to reduce the quantity of surface water entering the sewerage system in order to maximise the capacity for foul sewage to reduce the risk of sewer flooding.

Limiting the opportunity for surface water entering the foul and combined sewer networks is of critical importance to Thames Water. Thames Water have advocated an approach to SuDS that limits as far as possible the volume of and rate at which surface water enters the public sewer system. By doing this, SuDS have the potential to play an important role in helping to ensure the sewerage network has the capacity to cater for population growth and the effects of climate change.

SuDS not only help to mitigate flooding, they can also help to: improve water quality; provide opportunities for water efficiency; provide enhanced landscape and visual features; support wildlife; and provide amenity and recreational benefits.

With regard to surface water drainage, Thames Water request that the following paragraph should be included in the Neighbourhood Plan "***It is the responsibility of a developer to make proper provision for surface water drainage to ground, water courses or surface water sewer. It must not be allowed to drain to the foul sewer, as this is the major contributor to sewer flooding.***"

Water Efficiency/Sustainable Design

The Environment Agency has designated the Thames Water region to be "seriously water stressed" which reflects the extent to which available water resources are used. Future pressures on water resources will continue to increase and key factors are population growth and climate change.

Water conservation and climate change is a vitally important issue to the water industry. Not only is it expected to have an impact on the availability of raw water for treatment but also the demand from customers for potable (drinking) water. Therefore, Thames Water support the mains water consumption target of 110 litres per head per day (105 litres per head per day plus an allowance of 5 litres per head per day for gardens) as set out in the NPPG (Paragraph: 014 Reference ID: 56-014-20150327) and support the inclusion of this requirement in the Policy.

Thames Water promote water efficiency and have a number of water efficiency campaigns which aim to encourage their customers to save water at local levels. Further details are available on the our website via the following link:
<https://www.thameswater.co.uk/Be-water-smart>

It is our understanding that the water efficiency standards of 105 litres per person per day is only applied through the building regulations where there is a planning condition requiring this standard (as set out at paragraph 2.8 of Part G2 of the Building Regulations). As the Thames Water area is defined as water stressed it is considered that such a condition should be attached as standard to all planning approvals for new residential development in order to help ensure that the standard is effectively delivered through the building regulations.

Within Part G of Building Regulations, the 110 litres/person/day level can be achieved through either the 'Calculation Method' or the 'Fittings Approach' (Table 2.2). The Fittings Approach provides clear flow-rate and volume performance metrics for each water using device / fitting in new dwellings. Thames Water considers the Fittings Approach, as outlined in Table 2.2 of Part G, increases the confidence that water efficient devices will be installed in the new dwelling. Insight from our smart water metering programme shows that household built to the 110 litres/person/day level using the Calculation Method, did not achieve the intended water performance levels.

Proposed policy text:

“Development must be designed to be water efficient and reduce water consumption. Refurbishments and other non-domestic development will be expected to meet BREEAM water-efficiency credits. Residential development must not exceed a maximum water use of 105 litres per head per day (excluding the allowance of up to 5 litres for external water consumption) using the ‘Fittings Approach’ in Table 2.2 of Part G of Building Regulations. Planning conditions will be applied to new residential development to ensure that the water efficiency standards are met.”

Site Allocations

There are no new allocations in the draft Neighbourhood Plan and the level of information does not enable Thames Water to make an assessment of the impact the proposed development will have on the waste water/sewerage network infrastructure and sewage treatment works. To enable us to provide more specific comments we require details of the type and scale of development together with the anticipated phasing.

We recommend Developers contact Thames Water to discuss their development proposals by using our pre app service via the following link: <https://www.thameswater.co.uk/developers/larger-scale-developments/planning-your-development/water-and-wastewater-capacity>

It should be noted that in the event of an upgrade to our sewerage network assets being required, up to three years lead in time is usual to enable for the planning and delivery of the upgrade. As a developer has the automatic right to connect to our sewer network under the Water Industry Act we may also request a drainage planning condition if a network upgrade is required to ensure the infrastructure is in place ahead of occupation of the development. This will avoid adverse environmental impacts such as sewer flooding and / or water pollution.

We recommend developers attach the information we provide to their planning applications so that the Council and the wider public are assured wastewater and water supply matters for the development are being addressed.

We trust the above is satisfactory, but please do not hesitate to contact David Wilson on the above number if you have any queries.

Yours faithfully,

David Wilson
Thames Water Property Town Planner